

Certificate

EC-Type-Examination

acc. to Directive 97/23/EC

Zertifikat Nr.: **01 202 642-B-11028**

Name and address of the manufacturer:

Goetze KG
Armaturen
Postfach 448
71604 Ludwigsburg

We hereby certify, that the type example mentioned below meets the requirements of the Directive 97/23/EC.

Tested acc. to Directive 97/23/EC:

EC-Type-Examination (Module B)

Test report No.:

642-11-318

Description of type example:

Safety Valve

Design: direct acting, springloaded

Type: 851 P, 851 N, 851 T
451 P, 451 N, 451 T und 860

Medium: Dangerous and Undangerous Steam and Gases (fluid group 1 and 2)

Sizes: DN 15, DN 20, DN 25, DN 32, DN 40, DN 50

Set Pressure: 0,5 up to 25 bar

Valid until:


12th December 2021

The CE marking must not be affixed and the Declaration of Conformity not be issued prior to completion of the corresponding conformity assessment procedure according to Directive 97/23/EC.

Aachen, 05th December 2011


Dipl.-Ing. Manfred Rönning

TÜV Rheinland-Certification Body for Pressure Equipment
TÜV Rheinland Industrie Service GmbH, Notified Body, ID-No. 0035
Am Grauen Stein, D-51105 Köln



Außenstelle
Krefelder Str. 225, 52070 Aachen, Tel. ++49-241/1825-870
E-Mail: service-is-mw@de.tuv.com